



TOWN OF HADLEY
DEPARTMENT OF PUBLIC WORKS
WASTEWATER DIVISION
230 MIDDLE ST, P.O. BOX 406
HADLEY, MA 01035-0406

Grease Trap Fact Sheet & Requirements
(January 27, 2009)

- Exterior Grease traps on all food service establishments will be required; this requirement will be retroactive
- Any new food establishment must have an exterior trap installed as part of construction
- Existing facilities will be ordered to retro-fit when they:
 - Renovate the establishment
 - Are identified as a contributor to grease build up in a section of municipal sewer
 - When it is noted that interior grease interceptors are not being properly maintained
- The minimum size grease trap allowed is a 1,500-gallon trap – actual sizing is based on the requirements set forth in Title 5
- Exterior grease traps must be cleaned quarterly, as needed, or as determined by Wastewater Treatment Plant personnel

DISCLAIMER: This fact sheet is for general informational purposes and guidance only. If any statements conflict with the actual regulations, the regulations shall prevail. It is the applicant or user's responsibility to consult the regulations for full text and applicability.